



LGAI

LGAI Technological Center, S.A.
Campus UAB s/n
Apartado de Correos 18
E - 08193 Bellaterra (Barcelona)
T +34 93 567 20 00
F +34 93 567 20 01
www.applus.com



V/F
Page 1

Bellaterra: 30th March, 2012
File number: **12/4700-424 Part 2 English Version**
Petitioner's reference: Milin B.V.
Postbus 1414
3430 BK Nieuwegein
Nederland / The Netherlands



CLASSIFICATION REPORT

1- PRODUCT CHARACTERISTICS

Commercial product reference: Wonderboard

Glass fiber reinforced polyester, with a 1 mm in thickness, 1.68 Kg/m² in grammage, translucent colour and smooth appearance.

This document may only be copied in full.
Only reports with an original signature on their respective certified copies will be legally valid.
This document has 3 pages, of which -- are annexes.



2- CLASSIFICATION AND DIRECT APPLICATION FIELD

This classification has been made in compliance with the procedures provided in Standard UNE-EN 13501-1:2007+A1:2010: "Classification in terms of the behaviour to fire of construction products and building elements. Part 1: Classification made from the data gathered during fire reaction tests".

2.1- Test Reports

Name of the Laboratory	Applus - LGA
Name of Petitioner	Milin B.V.
Test Report Number	12/4700-424 Part 1
Testing method	UNE-EN-ISO 11925-2:2011 EN 13823:2010

2.2- Results of the tests

Testing method	GLASS FIBER REINFORCED POLYESTER			
	CRITERIA CLASS B	Nº OF TESTS	MEAN VALUE	COMPLIANCE
UNE-EN-ISO 11925-2:2011	$F_s \leq 150$ mm within 60 s	6	$F_s < 150$ mm	YES
	$FIGRA_{0,2 MJ} \leq 120$ W/s	3	96.08	YES
EN 13823 :2010	LFS < edge of sample	3	< to edge	YES
	$THR_{600s} \leq 7.5$ MJ	3	1.21	YES
	CRITERIA subclass 's1'	Nº OF TETS	MEAN VALUE	COMPLIANCE
	$SMOGRA \leq 30$ m ² /s ²	3	123.65	NO
	$TSP_{600s} \leq 50$ m ²	3	183.06	NO
	CRITERIA subclass 's2'	Nº OF TESTS	MEAN VALUE	COMPLIANCE
	$SMOGRA \leq 180$ m ² /s ²	3	123.65	YES
	$TSP_{600s} \leq 200$ m ²	3	183.06	YES
	CRITERIA subclass 'd0'	Nº OF TESTS	MEAN VALUE	COMPLIANCE
	Fall of droplets/particles in flames within 600 s	3	NO	YES

**Calculation is done in accordance with note of section A.6.1.2 of test standard.*



File n° **12/4700-424 Part 2**

Page 3

CLASSIFICATION

With regard to its behaviour when reacting to fire, the product Wonderboard is classified as follows:

Behaviour to fire	Smoke production	Droplets in flames
B	s 2	d 0

Fire reaction classification: CLASS B s2 d0
This classification is only valid for the final conditions of use described in the present report.

“Point “2.3- Field of Application” bellows falls beyond the ENAC accreditations scope”.

2.3- Field of application

- This classification is valid for the following product parameters:

The classification is only valid for the product characteristics shown.

- This classification is valid for following final conditions of use:

Roof fanlight or vertical enclosure.

2.4- Restrictions

This classification standard should not be construed as a standard approval or certification of the product.

Firmado digitalmente
por Jordi Mirabent
Junyent

Firmado digitalmente
por Vanessa Tutusaus
Domingo

Chief of the fire laboratory
LGAI Technological Center S.A.

Chief technician
LGAI Technological Center S.A.

The results refer exclusively to the samples tested at the time and under the conditions indicated.

Applus+ guarantees that this task has been carried out in compliance with the requirements of our Quality and Sustainability System, and furthermore, that the contractual terms and legal regulations have been complied with. In the framework of our improvement programme, we would appreciate any comments you may deem appropriate. These should be addressed to the manager who signs this document, or to the Quality Director of Applus+, at the following address: satisfaccion.cliente@appluscorp.com

In the event of litigation, the Spanish version will be valid